

THREE PART SHORT FORM SPECIFICATIONS (CSI)

AS400 PERFORATED VISTA SLIDING GRILLE

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Sliding Grille – Side Folding Door and Grille

1.2 RELATED SECTIONS

- A. Section 033000 – Concrete: Concrete openings.
- B. Section 042000 – Masonry: Masonry openings.
- C. Section 055000 – Metal Fabrications: Supporting members.
- D. Section 061000 – Carpentry: Framing and trim.
- E. Section 092500 – Gypsum Drywall: Opening finish.

1.3 REFERENCES

- A. ASTM B 221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.

1.4 DESIGN / PERFORMANCE REQUIREMENTS

- A. Stacking:
 - 1. Minimum stacking shall be 1.05 inches/linear foot (87.5 mm/meter) of opening plus 3.5 inches (89 mm) for each locking member.
 - 2. Grille support must be designed to carry the weight of a fully stacked door at any point along its length. Support is to carry the total weight / the total stacking and is expressed as lbs./lin. ft.
- B. Lintel Deflection: Accommodate deflection of lintel to prevent damage to components, deterioration of seals, or movement between door frame and perimeter framing.
- C. Thermal Movement: Design sections to permit thermal expansion and contraction of components to match perimeter opening construction.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00.
- B. Shop Drawings: Indicate opening dimensions, curves, type of locking posts, elevations and framed opening tolerances.
- C. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: A company that specializes in the manufacturing of the folding grille products required for the project with a minimum of 10 years documented experience.

- B. Installer Qualifications: Contractor that has minimum of two years documented experience installing folding grille products similar to those specified.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Protect finished surfaces with wrapping. Do not use adhesive papers or sprayed coatings that bond to substrate when exposed to sunlight or weather
- C. Protect materials from exposure to moisture. Do not deliver until after wet work is complete and dry.
- D. Store materials in a ventilated weather tight location.

1.8 COORDINATION

- A. Coordinate Work with other operations and installation of finish materials to avoid damage to the materials.

1.9 WARRANTY

- A. Manufacturers standard limited product warranty for a period of two years.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Amstel Manufacturing (1993) Inc
128 Centre Street East, Richmond Hill, Ontario. L4C 1A6. Canada.
Ph. 1-800-663-6206 or 905-508-0855 Fx. 1-866-525-1304 or 905-508-8487
E. projects@amstel-doors.com
W. www.amstel-doors.com.
- B. Substitute products by the following manufacturers are accepted:
 - 1. Cornell Iron Works Inc.
 - 2. The Cookson Company, Inc.
 - 3. McKinlay Door Sales
- C. Requests for substitutions will be considered in accordance with provisions of Section 01 60 00.

2.2 MATERIALS

- A. AS400 PERFORATED VISTA Sliding Security Grille
 - 1. Curtain:
 - a. Panels to have full height butt hinges on 7 inches (178 mm) centers.
 - b. Panels to have 4 inches (102 mm) high truss-like plates at the top and bottom of the closure.
 - c. Panel Inserts are separated by 1" height aluminum extrusions with "T" shaped ends to fit into full height aluminum extruded channels for added strength.
 - d. Constructed of 6 inches (152 mm) wide by 1/8 inch (3.2 mm) thick steel panel inserts with perforated round holes set in a staggered pattern.
 - e. Perforated Panels are sandwiched between P.V.C. gaskets.

2. Weight: AS400 Perforated Vista: 2.0 lbs./sq. ft. (9.7 kg/sq.m).
3. Aluminum is to be 6063 aluminum alloy with T-5 temper conforming to ASTM B 221.
4. Locking:
 - a. Lead Posts:
 - 1) Standard:
 - (a) Provide (#7) hook bolt post with a concealed hook bolt lock activated by a keyed cylinder or thumb turn that engages hook bolt into full height wall channel.
 - 2) Options:
 - (b) Provide (#2) top and bottom post with top rod and bottom ratcheted rod activated by a keyed cylinder or thumb turn. Provide rubber bumper at edge of locking post.
 - b. Intermediate posts:
 - 1) Standard:
 - (a) Provide (#4) intermediate posts at maximum of 10 feet (3048 mm) of curtain length for floor mounting condition. For counter mounts and at each curve provide intermediate posts at maximum of 6 feet (1828 mm) of curtain length.
 - 2) Options:
 - (b) Provide (#3) intermediate posts with an adjustable manually operated drop bolt with cylinder locks.
 - c. End Posts:
 - 1) Standard:
 - (a) Provide (#6) self-locking post with an attached full height protection plate, self-locking into a steel V-stop mounted to the floor or counter inside the storage pocket.
 - 2) Options:
 - (b) Provide (#7) hook bolt post with a concealed hook bolt lock activated by a keyed cylinder or thumb turn that engages the hook bolt into full height wall channel.
 - (c) Provide (#8) fixed end post.
 - (d) Provide (#2) top and bottom post with top rod and bottom ratcheted rod activated by a keyed cylinder or thumb turn. Provide rubber bumper at the edge of the locking post.
 - d. Bi-parting Posts:
 - 1) Standard:
 - (a) Provide (#5) bi-parting posts for sliding grilles at maximum 30'0" wide intervals. One lock member will retain a hook-bolt deadlock activated by keyed cylinder or thumb-turn cylinder. A second intermediate locking member is provided with a steel floor bolt and shall include a full height channel to accept the hook-bolt deadlock.
 - 2) Options:
 - (b) Provide (#5) bi-parting posts – additional posts can be added at intervals shorter than 30'0" wide.

5. Emergency Egress Door (Optional):
 - a. Emergency Egress provided as required. Where local by-laws dictate provide fall-away man-door egress operable by means of thumb-turn. Door should not be used as regular means of passage.

6. Floor Sockets:
 - 1) Standard:
 - (a) Supply Stainless Steel dustproof floor sockets for all drop bolts.
 - 2) **Optional:**
 - (b) **Custom shortened floor sockets available if required.**

7. Track:
 - a. Overhead track shall be 1.3 inches (33 mm) wide by 1.8 inches (46 mm) high and sized to accept 1-1/8 inches (29 mm) diameter roller trolleys.
 - b. Rollers bear on 0.27 inch (7 mm) thick aluminum surface within the track.
 - c. Radius Track: Provide the following where indicated.
 - 1) Standard:
 - (a) Radius: 14.625 inches (372 mm) in 90 degrees.
 - (b) Radius: 14.625 inches (372 mm) in 45 degrees.
 - 2) **Optional:**
 - (c) **Radius: 10.625 inches (270 mm) in 90 degrees.**
 - (d) **Radius: 36 inches (914 mm) in 90 degrees.**
 - (e) **Radius: 48 inches (1219 mm) in 90 degrees.**

8. Factory Finishes:
 - a. Use two letter suffix to denote required door finish.
 - 1) Standard:
 - (a) AA Clear Anodized, 0.0004 inch (10 micron) clear anodizing.
 - 2) **Options:**
 - (b) WH White, Duracron acrylic paint K1285
 - (c) MB Medium Bronze, Duracron acrylic paint K71232
 - (d) BL Black, Duracron acrylic paint K90421
 - (e) CC Custom Colour, Duracron acrylic paint or Powder Coat Finish.

2.3 ACCESSORIES

- A. Fasteners: Galvanized or corrosion resistant steel.

2.4 FABRICATION

- A. Size and fabricate grille assembly to allow for tolerances of rough framed openings, clearances, shim spacing and shims around perimeter of assemblies.
- B. Ensure joints and connections are flush and hairline.
- C. Accurately and rigidly fit joints and corners.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared and are able to carry the weight of the folded grille.
- B. Verify openings are ready to receive work and opening dimensions and clearances are as indicated on shop drawings.
- C. Provide full size template or CAD file for custom radius track prior to fabrication.
- D. If openings are the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces as recommended by the manufacturer for achieving the correct installation under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Attach frame and shims to perimeter opening to accommodate construction tolerances and other irregularities.
- C. Use anchoring devices that securely fasten sliding door assembly to wall and ceiling construction without distortion or imposed stresses.
- D. Separate aluminum and other corrodible surfaces from sources of corrosive or electrolytic action at points of contact with other materials.
- E. Adjust hardware for smooth operation.

3.4 CLEANING

- A. Remove protective material from factory finished surfaces.
- B. Remove temporary labels and visible markings

3.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION

SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE